


Wall			
Services	Coating on both sides with FLAMMOTECT-A	Fire resistance class	
Cables Ø ≤ 21 mm	≥ 100 mm × ≥ 0.75 mm dry film thickness	EI 60	
Cables Ø ≤ 50 mm		EI 60	
Cables Ø ≤ 80 mm		EI 60	
Cable bundles Ø ≤ 100 mm		EI 60	
Conduits made of steel Ø ≤ 16 mm		EI 60 U/C	
Conduits made of plastic Ø ≤ 16 mm		EI 60 U/U	

Floor			
Services	Coating on both sides with FLAMMOTECT-A	Fire resistance class	
Cables Ø ≤ 21 mm	≥ 100 mm × ≥ 0.75 mm dry film thickness	EI 60	
Cables Ø ≤ 50 mm		EI 60	
Cables Ø ≤ 80 mm		EI 60	
Cable bundles Ø ≤ 100 mm		EI 60	
Conduits made of steel Ø ≤ 16 mm		EI 60 U/C	
Conduits made of plastic Ø ≤ 16 mm		EI 60 U/U	



Wall		
Services	Coating on both sides with FLAMMOTECT-A	Fire resistance class
CommScope HELIAX®, Ø ≤ 51.1		EI 45 U/C / E 60 U/C
RFS CELLFLEX [®] , Ø ≤ 50.3	≥ 100 mm × ≥ 1.0 mm dry film thickness	EI 60 U/C
RFS RADIAFLEX®, Ø ≤ 48.2	, , , , , , , , , , , , , , , , , , , ,	EI 60 U/C
Floor		
Services	Coating on both sides with FLAMMOTECT-A	Fire resistance class
CommScope HELIAX°, Ø ≤ 51.1		EI 45 U/C / E 60 U/C
RFS CELLFLEX®, Ø ≤ 50.3	≥ 100 mm × ≥ 1.0 mm dry film thickness	EI 45 U/C / E 60 U/C
RFS RADIAFLEX®, Ø ≤ 48.2	,	EI 60 U/C

