## Electrical installation conduits made of plastic in wall and floor seals



Wall **NBR-plus** Fire Outer Number of wraps [n] Overlap Inside seal Outside [mm] [mm] seal [mm] [n] Wrap width Service diameter resistance [mm] class [mm] **Electrical installation conduits** made of plastic, single, ≤ 32 1 with/without cables  $\leq$  21 mm 47.5-50.0 12.5-15.0 62.5 2 EI 90 U/U ≤ 32, **Electrical installation conduits** made of plastic, bundled, bundled to 2 with/without cables  $\leq$  21 mm ≤ 100

Floor								
Service	Outer diameter [mm]	NBR-plus						Fire
		Wrap width [mm]	Number of wraps [n]	Overlap [mm]	Inside seal [mm]	Outside seal [mm]	Number of layers [n]	resistance class
Electrical installation conduits made of plastic, single, with/without cables ≤ 21 mm	≤ 32	125	1	_	75	50	1	EI 90 U/U
Electrical installation conduits made of plastic, bundled, with/without cables ≤ 21 mm	≤ 32, bundled to ≤ 100						2	