


Wall							
	Outer diameter [mm]	NBR-plus					
Services		Wrap width [mm]	Overlap [mm]	Inside seal [mm]	Outside seal [mm]	Number of layers [n]	Fire resistance class
Electrical installation conduits made of plastic, single, with/without cables ≤ 21 mm		2 × 62.5	or 0	2 × 30.0 or 1 × 60.0	2 × 32.5	2	EI 60 U/U
Electrical installation conduits made of plastic, bundled, with/without cables ≤ 21 mm	≤ 100.0	1 × 125.0					

Floor							
	Outer diameter [mm]	NBR-plus					
Services		Wrap width [mm]	Overlap [mm]	Inside seal [mm]	Outside seal [mm]	Number of layers [n]	Fire resistance class
Electrical installation conduits made of plastic, single, with/without cables ≤ 21 mm	≤ 32.0	2 × 62.5 oder 1 × 125.0	0	2 × 30.0 oder 1 × 60.0	2 × 32.5	2	EI 45 U/U / E 60 U/U
Electrical installation conduits made of plastic, bundled, with/without cables ≤ 21 mm	≤ 100.0						



Wall									
Services									
	Wrap width [mm]	Overlap [mm]	Inside seal [mm]	Outside seal [mm]	Number of layers [n]	Fire resistance class			
Bundles $\emptyset \le 40$ mm with single pipes $\emptyset \le 7$ mm	2 × 62.5	0	2 × 30.0 oder	2 × 32.5	1	EI 60 U/U			
Bundles $\emptyset \le 40$ mm with single pipes $\emptyset \le 14$ mm	1 × 125.0	U	1 × 60.0	2 ^ 32.3					
Floor									
Services	Wrap width [mm]	Overlap [mm]	Inside seal [mm]	Outside seal [mm]	Number of layers [n]	Fire resistance class			
Bundles $\emptyset \le 40$ mm with single pipes $\emptyset \le 7$ mm	2 × 62.5 or	or 0	2 × 30.0 or 1 × 60.0	2 × 32.5	1	EI 60 U/U			
Bundles $\emptyset \le 40$ mm with single pipes $\emptyset \le 14$ mm	1 × 125.0								
131 11 11 11									

